

Well control Panel bid specs

Well control panel to include the following:

- N1 stainless steel enclosure
- 50 HP circuit breaker
- 50 HP soft start motor starters
- Hand-off-auto switch
- Distribution block
- Pump run pilot light
- Transient voltage surge suppressor
- Phase monitor
- Elapse time meter
- Power supply
- Time delay relays
- Relays
- Starter trip pilot light
- Demand pilot light
- High turbidity pilot light
- Blower shutdown pilot light
- Interface circuitry
- Telemetry contacts

Electrical installation to include:

- Removal of existing control Panel
- Mounting of new panel
- Re-routing of existing conduit and wire as needed
- Interface blower control panel to new control panel